Zertifikat *Certificate*

Zertifikatsnummer *Certificate No.:*
R 50748508 0001

Berichtsnummer *Report No.:*
CN261GER 001

Genehmigungsinhaber *License Holder:*
Anhui Zhenghua Tong'an Fire Technology Co., Ltd
Building 1, No. 777 Wenzhong Road,
Modian Community, Hefei Xinzhan
High-Tech Development Zone,
Hefei City,
230000 Anhui
P.R. China

Fertigungsstätte *Manufacturing Site:*
Anhui Zhenghua Tong'an Fire Technology Co., Ltd
Building 1, No. 777 Wenzhong Road,
Modian Community, Hefei Xinzhan
High-Tech Development Zone,
Hefei City,
230000 Anhui
P.R. China

Prüfzeichen *Test Mark:*

TÜVRheinland® CERTIFIED
Type Approved
Safety
Regular Production
Surveillance
www.tuv.com
ID 1111323566

Geprüft nach *Tested according to:*
BS EN 15276-1:2019

Geräteidentifikation
Product Identification

Produkt: *Product:* Fixed fire fighting equipment (Condensed aerosol generator)

Modell: *Type:* Modelle sind auf nächste(r) Seite(n) gelistet / *Type designation(s) are listed on the next page(s)*

Technische Daten: *Technical Data:* Technical data(s) are listed on the next page(s)
ANLAGE (Appendix): 1

Gültig ab: *Valid from:* 2026-09-22

Ausstellungsdatum: *Date of issue:* 2026-09-22

Zertifizierungsstelle: *Certification body:*

TÜV Rheinland LGA Products GmbH
TÜVRheinland®
Zertifizierungsstelle

Kenny Shi

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg
http://www.tuv.com/safety E-mail: markcheck@tuv.com
Fax: +49 221 806-3935

® TÜV, TUEV and TUV are registered trademarks. Utilisation and application requires prior approval.

Zertifikat *Certificate*

Zertifikatsnummer *Certificate No.:*
R 50748508 0001

Berichtsnummer *Report No.:*
CN261GER 001

Produkt *Product:* Fixed fire fighting equipment
(Condensed aerosol generator)

Modell *Type:* **Bezeichnung** *Designation:*

ZHTA-3000-ET

```
Activation Device      : Electrical and Thermal Activation Device
Ratings for Activation : DC 24V, 1A （Electrical）
                         185±15°C （Thermal）
Service Life           : 15 years
Operating Temperature  : -45 ~ 80 °C
Mass of Solid
Aerosol-forming Compound: 3kg
```

TÜV Rheinland LGA Products GmbH
TÜVRheinland
Zertifizierungsstelle

® TÜV, TUEV and TUV are registered trademarks. Utilisation and application requires prior approval.